

CON 12-15
Doc #15700**SCHUPICK & DUNN, CPAs**
A Professional Corporation

13 N. Federal Ave.
P. O. Box 1486
Mason City, Iowa 50402
Phone (641) 424-5993
Fax (641) 424-3847
E-Mail: sd@mach3ww.com

FAX COVER SHEET

DATE: 3/29/01

TO: LAMBERT NNAD

FROM: TIM SCHUPICK

There are 4 pages with this fax transmission including this cover sheet. If you did not receive all of the pages in good condition, please call 641-424-5993.

FOLLOWING ARE THE LAB REPORTS
ON THE WELL WATER COLLECTED ON 1/11/01.

THANK YOU FOR YOUR PROMPT RESPONSE
TO MELANIE AT BANK OF AMERICA
YESTERDAY. MAY I REQUEST THAT YOU
DRAFT ANOTHER RESPONSE CONCERNING
YOUR DETERMINATION ON THESE LAB
RESULTS AND FAX IT TO HER AS SOON
AS POSSIBLE.

THANKS FOR ALL YOUR HELP IN THIS
MATTER. Tim S.




ANALYTICAL REPORT

January 30, 2001

Page 1 of 2

Report To: Bob Taylor Andrews Prestressed Concrete 1305 N 32nd St P O Box 33 Clear Lake, LA 50428	Sample Information: Work Order: 1101.0409 Sample No: 1100959 Date Collected: 01/11/01 01:30 PM Date Received: 01/12/01 12:21 PM Collector: Taylor, Bob Collector Phone: 515-357-5217 Matrix: water
---	--



Site Information/Sample Description: Andrews Prestressed Concrete 1305 N. 32nd St. Clear Lake, IA 01 Well #2 Dot Office	Comments:
--	------------------

Analyte	Analysis Result	MCL/LIA	Method	Analyst	Date Analyzed
Determination of regulated VOCs, A/S #1					
1,1,1-Trichloroethane	< 0.5 ug/L	200	EPA 524.2	EJW	01/15/01
1,1,2-Trichloroethane	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
1,1-Dichloroethylene	< 0.5 ug/L	7	EPA 524.2	EJW	01/15/01
1,2,4-Trichlorobenzene	< 0.5 ug/L	70	EPA 524.2	EJW	01/15/01
1,2-Dichloroethane	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
1,2-Dichloropropane	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
Benzene	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
Carbon Tetrachloride	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
cis-1,2-Dichloroethylene	< 0.5 ug/L	70	EPA 524.2	EJW	01/15/01
Dichloromethane	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
Ethylbenzene	< 0.5 ug/L	700	EPA 524.2	EJW	01/15/01
Monochlorobenzene	< 0.5 ug/L	100	EPA 524.2	EJW	01/15/01
o-Dichlorobenzene	< 0.5 ug/L	600	EPA 524.2	EJW	01/15/01
p-Dichlorobenzene	< 0.5 ug/L	75	EPA 524.2	EJW	01/15/01
Styrene	< 0.5 ug/L	100	EPA 524.2	EJW	01/15/01
Tetrachloroethylene	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01
Toluene	< 0.5 ug/L	1000	EPA 524.2	EJW	01/15/01
trans-1,2-Dichloroethylene	< 0.5 ug/L	100	EPA 524.2	EJW	01/15/01
Trichloroethylene	< 0.5 ug/L	5	EPA 524.2	EJW	01/15/01

< = less than; ug/L = ppb; mg/L = ppm

600 East 17th Street South
Newton, IA 50208 • 641-792-8451

3012 Ansbrough Avenue
Waterloo, IA 50701 • 319-235-4440

1304 Adams
Kansas City, KS 66103 • 913-321-7856

Keystone

LABORATORIES, INC.

MEMBER
ACIL


Work Order: 1101.0409

Sample No: 1100959

Report Date: 1/30/01

Sample Description

01 Well #2 Dot Office



Page 2 of 2


Analyte	Analysis Result	MCL/HA	Method	Analyst	Date Analyzed
Vinyl Chloride	< 0.5 ug/L	2	EPA 524.2	EJW	01/15/01
Xylenes (total)	< 0.5 ug/L	10000	EPA 524.2	EJW	01/15/01
Determination of regulated SOC's, A/S #3					
2,4,5-TP (Silvex)	< 0.5 ug/L	50	EPA 515.1	EPP	01/21/01
2,4-D	< 2 ug/L	70	EPA 515.1	EPP	01/21/01
Dalapon	< 2 ug/L	200	EPA 515.1	EPP	01/21/01
Dinoseb	< 0.5 ug/L	7	EPA 515.1	EPP	01/21/01
Pentachlorophenol	< 0.2 ug/L	1	EPA 515.1	EPP	01/21/01
Picloram	< 1 ug/L	500	EPA 515.1	EPP	01/21/01
Determination of regulated SOC's, A/S #4					
Alachlor	< 0.1 ug/L	2	EPA 507	EPP	01/17/01
Atrazine	< 0.1 ug/L	3	EPA 507	EPP	01/17/01
Simazine	< 0.1 ug/L	4	EPA 507	EPP	01/17/01
Determination of regulated SOC's, A/S #6					
Di(2-ethylhexyl) adipate	< 1 ug/L	400	EPA 525.2	EPP	01/24/01
Di(2-ethylhexyl) phthalate	< 1 ug/L	6	EPA 525.2	EPP	01/24/01
Determination of regulated SOC's, A/S #7					
Benzo(a)pyrene	< 0.02 ug/L	0.2	EPA 550	FWM	01/17/01

Keystone Laboratories, Inc.

< = less than; ug/L = ppb; mg/L = ppm

600 East 17th Street South
Newton, IA 50208 • 641-792-84513012 Ansborough Avenue
Waterloo, IA 50701 • 319-235-44401304 Adams
Kansas City, KS 66103 • 913-321-7856

Keystone
LABORATORIES, INC.



MEMBER
ACII

ANALYTICAL REPORT

Page 1 of 1

Certified Lab ID: 00051

Report To

Andrews Prestressed Concrete
1305 N. 32nd St
Clear Lake, IA 50428

Sample Information

Work Order: 2101.0247
Date Received: 01/12/01 02:55 PM
Collector: Taylor, Bob
Collector Phone: 515-357-5217
Report Date: 01/13/01

Site Information

Andrews Prestress Concrete

Comments

Sample No : Analyte	Description : Matrix	Date Collected : Analysis Result	Detection Limit	Method	Analyst	Date Analyzed
2100514	Conference Womens Room : Coliform Bacteria, total	1/11/2001 1:00:00 PM : water Absent		SM 9223 B-18P	TMS	01/12/01
	E. Coli	Absent		SM 9223 B-18P	TMS	01/12/01
2100515	Conference Mens Room : Nitrogen, Nitrate	1/11/2001 1:10:00 PM : water < 1. mg/L		1. SM 4500-NO3	KDE	01/12/01

Keystone Laboratories, Inc.

Tammy Satterlee

< = less than; ug/L = ppb; mg/L = ppm; mg/kg = ppm; MPN = Most Probable Number

Note: This report may not be reproduced except in full, without written approval of the laboratory.

600 East 17th Street South
Newton, IA 50208 • 641-792-8451

3012 Ansborough Avenue
Waterloo, IA 50701 • 319-235-4440

1304 Adams
Kansas City, KS 66103 • 913-321-7856