

STATE OF IOWA  
DEPARTMENT OF NATURAL RESOURCES  
Water Supply Engineering Section  
401 SW 7<sup>th</sup> Street, Suite M  
Des Moines, Iowa 50309-4611

WATER SUPPLY  
CONSTRUCTION PERMIT

**CON 12-15**  
**Doc #21697**

City of Cedar Rapids  
1111 Shaver Road Northeast  
Cedar Rapids, Iowa 52402

Permit No.: 2009-356W  
Project No.: W2009-429  
PWSID No.: 5715093

In accordance with the provisions of Sections 455B.173(9) and 455B.174(4) of the Iowa Code and 567—43.3(455B) of the Iowa Administrative Code, the Director of the Department of Natural Resources does hereby issue a permit for the construction of:

**2875 feet of 8-inch diameter and 400 feet of 6-inch diameter ductile iron water main along 26<sup>th</sup> Street Southeast south of Mount Vernon Road Southeast, 31<sup>st</sup> Street Southeast, from Mount Vernon Road Southeast to Meadowbrook Drive Southeast, and 14<sup>th</sup> Avenue Southeast, from Seely Avenue Southeast to Karen Drive Southeast, to replace existing mains as part of the Southeast Quad Water Main Replacement project in Cedar Rapids, Iowa.**

**NOTE: Due to contamination associated with Carriage Cleaners (3102 Mt. Vernon Rd SE, Site ID #397) and leaking underground storage tank (LUST) site 9LTJ88 (a former gas station at the same address), the department recommends installing gaskets – in the corresponding portion of the 31<sup>st</sup> Street water main segment – that are considered to be impermeable to organic contamination (e.g., nitrile gaskets).**

NOTICE: The issuance of this construction permit is based SOLELY on the engineer's certification that all aspects of design included in the project meet the requirements of all applicable state and federal laws and regulations. An advisory review of the plans and specifications may be made at a later date.

Construction of the project shall be initiated within one year of issuance of this permit or this permit is no longer valid. Within thirty days after completion of construction, the permit holder shall submit a certification by a registered professional engineer that the project was completed in accordance with the approved project documents.


Pursuant to Section 455B.174.4, Code of Iowa, you have the right to appeal any condition of this permit by filing with the Director of the Department of Natural Resources a notice of appeal and request for administrative hearing within thirty days of receipt of this permit.

If you have any questions, please contact Skipp Slattenow, P.E. via e-mail at [skipp.slattenow@dnr.iowa.gov](mailto:skipp.slattenow@dnr.iowa.gov) or by telephone at 515.725.0461.

**For the Department of Natural Resources**

Richard A. Leopold, Director

By:

  
Environmental Services Division

Date:

September 28, 2009

cc: Rochelle Cardinale, DNR – Underground Storage Tanks Section, Wallace Bldg (LUST #9LTJ88)  
Matt Culp, DNR – Contaminated Sites Section, Wallace Bldg (Site ID #397)  
HR Green Co, 8710 Earhart Ln SW, Cedar Rapids, IA 52404  
Field Office No.: 1 (Manchester)  
File: PWSID No. 5715093

34168 OCT02'09 AM 10:31