

STATE OF IOWA
DEPARTMENT OF NATURAL RESOURCES
WATER SUPPLY ENGINEERING SECTION
502 E 9TH STREET
DES MOINES, IOWA 50319

WATER SUPPLY
CONSTRUCTION PERMIT

BRIDGE DISTRICT TOWNHOMES LLC
ATTN JOE PIETRUSZYNSKI
6900 WESTOWN PKWY
WEST DES MOINES, IA 50266

Permit No.: 2018-0586W
Project No.: W2018-0569
PWSID No.: IA7727031

In accordance with the provisions of Sections 455B.173(9) and 455B.174(4) of the Iowa Code and 567—43.3(455B) of the Iowa Administrative Code, the Director of the Department of Natural Resources does hereby issue a permit for the construction of:

269 feet of 8-Inch diameter AWWA C900 DR 18 polyvinyl chloride (PVC) water main extension including all associated appurtenances in accordance with the plans and specifications, for the Bridge District Plat 2 project in DES MOINES, Iowa.

Note: Department standards require any water main installed in areas of groundwater contaminated by organic compounds must be constructed of materials which do not allow permeation of these compounds into the drinking water supply.

NOTICE: The issuance of this construction permit is based SOLELY on the engineer's certification that all aspects of design included in the project meet the requirements of all applicable state and federal laws and regulations. An advisory review of the plans and specifications may be made at a later date.

Construction of the project shall be initiated within one year of permit issuance or this permit is no longer valid, unless an extension is granted. A request for a permit extension must be requested within one year of permit issuance. Within thirty days after completion of construction, the permit holder shall submit a certification by a Professional Engineer licensed in Iowa that the project was completed in accordance with the approved project documents.

Pursuant to Section 455B.174.4, Code of Iowa, you have the right to appeal any condition of this permit by filing with the Director of the Department of Natural Resources a notice of appeal and request for administrative hearing within thirty days of receipt of this permit.

If you have any questions, please contact Lanie Boas, EI via e-mail at lanie.boas@dnr.iowa.gov or by telephone at (515) 725-8445.

FOR THE DEPARTMENT OF NATURAL RESOURCES
BRUCE TRAUTMAN, ACTING DIRECTOR

By:

Gabriel L. PE
Environmental Services Division

Date: September 07, 2018

- Cc: ☐ DES MOINES WATER WORKS, ATTN Michael McCurnin;
2201 GEORGE FLAGG PKWY, DES MOINES, IA 50321
☐ Engineering Resource Group Inc, Attn Doug Saltgaver,
2413 Grand Ave Ste 2, Des Moines IA 50312-5313
☐ Field Office No. 5 - Windsor Heights
☐ Files: PWSID No. IA7727031 (green folder)
☒ DNR Contaminated Sites (Site 2310 – River Hills Business Park)