



June 23, 2020

Robert Moeller
MidAmerican Energy
302 South Vine Street
Ottumwa, IA 52501

Dear Mr. Moeller,

This letter is to inform you that the Iowa Department of Natural Resources (Iowa DNR) has reviewed and approved the Underground Storage Tank Closure Report for the Ottumwa Service Center located at 302 South Vine Street, Ottumwa, Iowa.

The Iowa DNR had approved the necessity to close the underground tank (UST) in place due to the close proximity of the tank to the building. The Iowa DNR has also reviewed and approved the corresponding analytical results for soil and groundwater testing related to the in-place closure of the UST. Specifically, the results for soil which contained ethylbenzene and TEH as waste oil that did not exceed the Tier 1 standards and the benzene and diesel detected in groundwater in exceedance of the Tier 1 for actual groundwater ingestion but did not exceed the standards for potential groundwater ingestion. However no wells were identified within 1,000 feet of the site and the City of Ottumwa has an ordinance approved by Iowa DNR which would prohibit installation of new drinking water wells.

Please feel free to contact me if you have any questions at 1-515-725-8337

Regards

A handwritten signature in blue ink, appearing to read "Matt Cofg".

CC: Mike Smith, Supervisor, Solid waste and Contaminated Sites Section Iowa DNR
Diane Pals GDH Consultants, 11228 Aurora Avenue, Urbandale, IA 50322
Iowa DNR Field Office #6 Washington, Iowa