

STATE OF IOWA
DEPARTMENT OF NATURAL RESOURCES
Water Supply Engineering Section
502 E 9th Street
Des Moines, Iowa 50319-0034

WATER SUPPLY
CONSTRUCTION PERMIT

CITY OF CEDAR RAPIDS – UTILITIES DEPT
1111 SHAVER RD NE
CEDAR RAPIDS, IA 52402

Permit No.: 2022-0273W
Project No.: W2022-0183
PWSID No.: 5715093

In accordance with the provisions of Sections 455B.173(9) and 455B.174(4) of the Iowa Code and 567—43.3(455B) of the Iowa Administrative Code, the Director of the Department of Natural Resources does hereby issue a permit for the construction of:

1357 feet of 24-inch diameter, 352 feet of 12-inch diameter, 74 feet of 8-inch diameter, 159 feet of 6-inch diameter, and 50 feet of 4-inch diameter ductile iron water main with nitrile gaskets, primarily along Center Point Road Northeast, from Coe Road to Lincoln Avenue, including all associated appurtenances, in order to replace aged and deteriorated water mains as part of the corresponding road reconstruction project in Cedar Rapids, Iowa.

NOTE:

- **Fire hydrant drains must be at least 10 feet from sanitary sewers, storm sewers, and storm drains (*Recommended Standards for Water Works* [2012 Ed.], §8.4.4.c).**

NOTICE: The issuance of this construction permit is based SOLELY on the engineer's certification that all aspects of design included in the project meet the requirements of all applicable state and federal laws and regulations. An advisory review of the plans and specifications may be made at a later date.

Construction of the project shall be initiated within one year of permit issuance or this permit is no longer valid, unless an extension is granted. A permit extension request must be made within one year of permit issuance. Within thirty days after completion of construction, the permit holder shall submit a certification by a professional engineer licensed in Iowa that the project was completed in accordance with the approved project documents.

Pursuant to Section 455B.174.4, Code of Iowa, you have the right to appeal any condition of this permit by filing with the Director of the Department of Natural Resources a notice of appeal and request for administrative hearing within thirty days of receipt of this permit.

If you have any questions, please contact Skipp Slattenow, P.E. via e-mail at skipp.slattenow@dnr.iowa.gov or by telephone at 515.725.0461.

For the Department of Natural Resources

Kayla Lyon, Director

By: _____
Environmental Services Division

Date: March 31, 2022

cc: DNR – Underground Storage Tanks Section, Wallace Bldg (LUST #: 9LTH92 & 9LTI94)
Matt Culp, DNR – Contaminated Sites Section, Wallace Bldg (Site ID #2334)
Shoemaker & Haaland, 329 10th Ave SE, Ste 215, Cedar Rapids, IA 52401
Field Office No.: 1 (Manchester)
File: PWSID No. 5715093