

**IOWA DEPARTMENT OF NATURAL RESOURCES  
ADDENDUM No. 1  
LAND & WATERS BUREAU**

VIKING LAKE STATE PARK  
OFFICE & STORAGE BUILDING  
MONTGOMERY COUNTY, IOWA  
PROJECT NUMBER: 17-04-69-02

November 9, 2018

*This Addendum is issued to modify, explain or correct the original Drawings and Specifications, and is hereby made a part of the Contract Documents. Please attach this Addendum to the Project Manual in your possession. Insert the number and issue date of this Addendum in the blank space provided on the Proposal Form.*

**Substitutions:**

1. Firestone UC-14, 24 gauge, roof is an acceptable substitution to the specified product.
  2. Firestone Clad-Gard R metal underlayment is an acceptable substitution to the specified product.
  3. Firestone Flush Panel soffit is an acceptable substitution to the specified product.
  4. R-Control Structural Insulated Panel is an acceptable substitution to the specified product.
  5. Clopay Commercial overhead door, model 3720, is an acceptable substitution to the specified product.
  6. Clopay Commercial overhead door, model 524, is an acceptable substitution to the specified product.
- 
- Please see attached addendum from KCL Engineering for more information.

IDNR  
Viking Lake State Park – New Office and Storage Building  
Addendum #1  
November 9, 2018

This addendum is issued to modify, clarify, or amend the original Project Drawings and Specifications and is hereby made part of the Contract Documents. The Contractor shall be responsible for incorporating items in this Addendum to the Work. The following shall take precedence over anything to the contrary in the Drawings or Specifications.

CONSULTING ENGINEERS

Mechanical  
Electrical  
Plumbing  
Lighting  
Technology

Mechanical – Approved Manufacturers:

The following shall be added to specifications as approved manufacturers:

<u>Equipment Type</u>	<u>Manufacturer</u>
15738 – Split System AC units	Samsung
16910 – Electric Hand Dryers	American Dryer, World Dryer

End of Mechanical and Electrical Addendum.