

DNR FAIRGROUND
ARCHERY BUILDING AND COURTYARD IMPROVEMENTS
POLK COUNTY, IOWA
PROJECT NUMBER: 24-05-77-01

December 4, 2023

This Addendum is issued to modify, explain or correct the original Drawings and Specifications, and is hereby made a part of the Contract Documents. Please attach this Addendum to the Project Manual in your possession. Insert the number and issue date of this Addendum in the blank space provided on the Proposal Form.

Clarifications:

- A. The finish floor elevation of the archery building shall be 803.0' as shown on the Civil plans.

- **The following two addenda were prepared by LT Leon & Associates and KCL Engineering. Please review these addenda for more information.**



ENGINEERING. CONSERVATION. PLANNING

PROJECT: Archery Building and Courtyard Improvements for DNR Fairgrounds
ADDENDUM #: 1
DATE: 11/30/2023

TO: Iowa DNR & All Plan Holders of Record

This addendum is issued to accept the request to supply the ‘Interlock: Holland-Eco Paver’ as an approved ‘or equal’ product, in addition to the paver options provided in the original bid documents. The acceptance of this product is only acceptable as long as the 3-1/8” paver thickness requirement per the Contract Documents is met. This Addendum forms a part of the Contract Documents.

The specifications, contract documents, and contract drawings prepared for this project are hereby modified, amended, or clarified in the following particulars:

Addendum Index:

Specifications	Section(s)	32 14 13 Permeable Pavers
Drawings	Sheet(s)	NA

Attachment ID	Section/Drawing	Description
NA	NA	NA

Description:

- See Specifications section 32 14 13 Permeable Pavers for requirements pertaining to supplying and installing permeable pavers per this project.

IDNR
State Fairgrounds Archery Building
Addendum 1
November 30, 2023

This addendum is issued to modify, clarify, or amend the original Project Drawings and Specifications and is hereby made part of the Contract Documents. The Contractor shall be responsible for incorporating items in this Addendum to the Work. The following shall take precedence over anything to the contrary in the Drawings or Specifications.

Electrical Drawings:

1. Drawing E-200 – ONE-LINE AND DETAILS, LUMINAIRE SCHEDULE:
 - a. **MODIFY** Type F1 to be HEM-4'-**30K**-ML-RFA-E-U-XEHC in lieu of HEM-4'-**40K**-ML-RFA-E-U-XEHC.
 - b. **CLARIFY** Type F1 lumen column to read **5000** lumens.
 - c. **MODIFY** Type F4 to be **HC6**-07-D010 in lieu of **HC5**-07-D010 .
 - d. **MODIFY** Type F4 trim to be 61-WD-**H** in lieu of 61-WD-**WB** .
 - e. **CLARIFY** Type W2 lumen column to read **1700** lumens.

Electrical – Approved Manufacturers:

The following shall be added to specifications as approved manufacturers:

<u>Light Fixture Type</u>	<u>Manufacturer</u>
F2	LLI OWG, with LLI CW4 Controller
F4	LITHONIA LDN6

End of Electrical Addendum.