

HICKORY HILLS PARK  
CASEY LAKE RESTORATION  
TAMA COUNTY, IOWA  
PROJECT NUMBER: 24-05-86-01

September 18, 2023

This Addendum is issued to modify, explain or correct the original Drawings and Specifications, and is hereby made a part of the Contract Documents. Please attach this Addendum to the Project Manual in your possession. Insert the number and issue date of this Addendum in the blank space provided on the Proposal Form.

Specifications:

- A. Replace paragraph 2.2-E.2 in specification 33-46-16 with the following:

‘All joints shall be sealed with butyl mastic or gasketed joints. At minimum, the first three joints from the downstream end shall be tied, unless specified otherwise on Plans.’

Other:

- A. CAD files for the project are available upon request. Contact Dan Jensen at Shive-Hattery to request files. [djensen@shive-hattery.com](mailto:djensen@shive-hattery.com) or 515.422.5536