NBST 123193

City of Burlington WW

3-21-2022

Report received by Public Works approx. 4:30 PM that a sewer outflow occurred at 61 Midtown Lane (apartment complex). City investigation determined problem to be in a private sewer. Management contacted a sewer cleaning company. Sewer cleaning company stopped the outflow, company did not see any one cause for the backup. Manager said Lyme will be applied to ground at closest manhole.

3-23-2022

Violation of NPDES Permit limit for total residual chlorine- Mass (43.23lbs) reported on 3-25 via phone and email.

3-23-2022

Reported to Public Works approx. 8:00 AM from residence at 1821 S Main of sewer back up. It was determined that the cleanout on City sewer had collapsed creating the back up. Approx. 5 to 10 gallons of sewage pooled in basement and was washed down sewer. Repair to pipes were made.