Comlan Ridge HOA
Johnson Co Semi Rept

Sevig Utility Co.
P.O. Box 409
Walford, IA 52351
319-846-5550 Phone
319-846-2713 Fax



December 29, 2009

2nd 2-24-10

Mr. Paul Brandt & Mr. Jon Ryk
IDNR Water Supply – Field Office 6
1023 W Madison
Washington, IA 52353

Dear Paul & Jon:

Attached is my response to your recent survey of Public Water Supply 5280303.

Significant Deficiencies:

Item 1 – The hydropneumatic storage tank drain redone according to Jon's specifications.

Item 2 – The owner of the geothermal system said that it is a separate system and is not connected to the potable water system.

Item 3 – We have a sampling plan on file in our office.

Minor Deficiencies:

I have enclosed 4 copies of the Water Operation Certification Affidavit.

Recommendations:

The bolts were tightened on the well cap.

If you have any questions or need additional information, please contact me at 319-846-5550.

Sincerely,

Gordon Sevig,
President