Make It Yours
KEOKUK
IOWA
CITY OF KEOKUK

RECEIVED
MAR 30 2011
IOWA DEPARTMENT OF
NATURAL RESOURCES
FO6

March 29, 2011

At 9:00 A.M. , Tuesday, March 29, the Bank Street Lift Station was shut down due to the Mississippi River backing into the collection system through CSO 13. The river is at 13 feet river stage and the CSO 13 flapper is not sealing.

Approximately 8000 gpd of sanitary sewage is diverted to the river through CSO 006 at the lift station until the river recedes.

This information was reported to Paul Brandt at IDNR Region 6 approximately 9:30 A.M. on March 29.

MUNICIPAL BUILDING • 415 BLONDEAU ST. • P.O. BOX 400 KEOKUK, IA 52632
PHONE 319-524-2050 • FAX 319-524-1365 • WWW.CITYOFKEOKUK.ORG