Lee, Brian [DNR]

From: Keokuk WPC [chuckpietscher@cityofkeokuk.org]
Sent: Wednesday, October 31, 2012 8:31 AM
To: Lee, Brian [DNR]
Subject: SSO

As reported to Field Office 6 within the 12 hour time limit, the City of Keokuk has one SSO on October 8. The overflow was at CSO 014 at 8:30 AM
into the Mississippi due to a buildup of leaves and debris. The blockage was removed within a half hour with approximately 5000 gallons lost.

Chuck Pietscher
Keokuk WPC
1000 Mississippi Drive
PO Box 400
Keokuk, IA 52632-0400
Phone (319) 524-3412
Fax (319) 524-2642