Brandt, Paul [DNR]

From: Brandt, Paul [DNR]
Sent: Tuesday, April 08, 2014 1:41 PM
To: 'Fred Doggett'
Subject: RE: Washington WWTP's automated effluent valve and UV equipment

Fred – good news, thanks

PAUL BRANDT **Environmental Specialist Senior**
Iowa Department of Natural Resources
P 319.653.2135 | F 319.653.2856 | paul.brandt@dnr.iowa.gov
1023 W. Madison | Washington, IA 52353
WWW.IOWADNR.GOV
Leading Iowans in Caring for Our Natural Resources.

From: Fred Doggett [mailto:fdoggett@washingtoniowa.net]
Sent: Tuesday, April 08, 2014 1:37 PM
To: Brandt, Paul [DNR]
Subject: Re: Washington WWTP's automated effluent valve and UV equipment

Hi Paul,

The repaired automated effluent valve was back in service around 11:30 a.m. on the 7th. The UV equipment was in service around 10:15 a.m. on the 8th.

Fred

On Thu, Apr 3, 2014 at 3:23 PM, Fred Doggett <fdoggett@washingtoniowa.net> wrote:
Will do, Thanks Paul!

On Thu, Apr 3, 2014 at 3:18 PM, Brandt, Paul [DNR] <Paul.Brandt@dnr.iowa.gov> wrote:

Fred – you can leave the UV unit out until next week, but get it on-line as soon as possible once you get the circuit board. If it is going to take longer than middle of next week, let us know. Also keep us posted on when the parts get in and when you get the unit back on-line.

PAUL BRANDT **Environmental Specialist Senior**
Iowa Department of Natural Resources
P 319.653.2135 | F 319.653.2856 | paul.brandt@dnr.iowa.gov
1023 W. Madison | Washington, IA 52353

From: Fred Doggett [mailto:fdoggett@washingtoniowa.net]
Sent: Thursday, April 03, 2014 9:51 AM
To: Brandt, Paul [DNR]
Cc: Steve Lee; Rob Baker; Jason Whisler; Brent Hinson
Subject: Washington WWTP's automated effluent valve and UV equipment

Hi Paul,

I just got off the phone with the service rep repairing our automated effluent valve.They found a bad motor starter and also a circuit board that was bad. They had the motor starter in stock but had to order the circuit board but they haven't received it yet.

They estimated the repairs to be completed and the valve back in service by the middle of next week.

Wondering if we can leave the UV equipment out of service until the valve is back in service or does it to need in service before then. You can let me know. Thanks!

Fred E. Doggett, WWTP Supt

City of Washington, IA

215 East Washington Street

Washington, IA 52353

Phone (319) 653-2638

Fax (319) 653-5273

--