Lee, Brian <brian.lee@dnr.iowa.gov>

96074

SSO report

2 messages

Bob Milroy <bobmilroy@cityofclintoniowa.us> Mon, Sep 11, 2017 at 9:51 AM
To: "Lee, Brian [DNR] (Brian.Lee@dnr.iowa.gov)" <Brian.Lee@dnr.iowa.gov>

Brian

On Friday Sept 8th around 1420 ,I reported an SSO at Main Street and Grant. I reported the SSO as a precautionary measure since it was on Friday afternoon and I didn't want to wait until you guys had gone home. It turned out to be a 6" water main break that ran right alongside the railroad tracks. It did cave in our manhole and we were forced to bypass pump over the weekend. At no time did any wastewater leave the collection system. A new manhole is being installed today and we should have everything back to normal.

Thanks

Robert D. Milroy

Water Quality Superintendent

City of Clinton, Iowa 52732

563-243-4064

Lee, Brian <brian.lee@dnr.iowa.gov> Mon, Sep 11, 2017 at 9:54 AM
To: Jeffrey Thomann <jeffrey.thomann@dnr.iowa.gov>, Terry Jones <terry.jones@dnr.iowa.gov>

FYI - I printed this for their file.

Brian Lee | Environmental Specialist
Iowa Department of Natural Resources
P 319-653-2135 | F 319-653-2856 | C 319-461-8849
Field Office #6 | 1023 W. Madison St. | Washington, IA 52353
www.iowadnr.gov

[Quoted text hidden]