iowa.gov

Kacer, Jim <jim.kacer@dnr.iowa.gov>

Basement Backup on March 30, 2018

Perry Thompson <perrythompson@cityofclintoniowa.us> Tue, Apr 3, 2018 at 10:39 AM
To: "jim.kacer@dnr.iowa.gov" <jim.kacer@dnr.iowa.gov>
Cc: Bob Milroy <bobmilroy@cityofclintoniowa.us>

Jim,

At approx. 4:10 PM on March 30, 2018, we were notified about a basement back-up at 3510 Cleveland, Clinton, Iowa. We sent a crew right away and jetted the sewer line. We found a blockage of tree root balls. We had it flowing normally by 5:15 PM.

The amount by-passed is unknown.

I called in this report at around 5:32 PM on March 30, 2018.

Respectfully,

Perry L. Thompson

Water Quality Assistant Superintendent

City of Clinton, Iowa

Phone: 563.243.4064 X106

Cell: 563.559.0661