IOWA DEPARTMENT OF NATURAL RESOURCES
FIELD SERVICES AND COMPLIANCE BUREAU
FIELD OFFICE #2 - MASON CITY IOWA

DATE: **September 4, 2024**

TO: **The Record**

FROM: **Jeremy Klatt** JK

SUBJECT: **Eagle Grove Bypassing Summary**
Complaint #33875

I conducted a review of DNR files on the City of Eagle Grove and have summarized the reported bypasses and basement backups from January of 2020 to present (August 2024). A similar compliance review was conducted in 2019 for the years 2014-2019 and was summarized in a memo dated September 4, 2019.

During this period, the City reported the following bypasses:

YEAR	DATE REPORTED	ESTIMATED GALLONS
2024	7/6/2024	10.5 million gallons
2024	7/2/2024	395,200 gallons
2024	6/22/2024	737,155 gallons
2024	6/19/2024	25,000 gallons
2024	5/21/2024	38,500 gallons
2024	5/9/2024	160,125 gallons
2024	5/7/2024	105,000 gallons
2024	5/4/2024	228,058 gallons
2024	5/2/2024	48,000 gallons
2024	3/25/24	146,964 gallons
2023	05/13/2023	41,706 gallons
2022	*No Bypasses reported*	
2021	08/21/2021	48,000 gallons
2020	05/26/2020	28,800 gallons
2020	03/20/2020	2.2 million gallons

During this review period, the City of Eagle Grove received three (3) Notice of Violation letters regarding prohibited bypasses. During the period of 2014-2019, the City received nine (9) Notice of Violation letters regarding bypassing.