# CITY OF FORT DODGE

**ENGINEERING DIVISION**

Municipal Building, 819 1st Avenue South, Fort Dodge, Iowa 50501


August 8, 2013


RECEIVED
AUG - 9 2013
IOWA DNR
FIELD OFFICE 2


Iowa Department of Natural Resources
Attn: Mr. David Knoll
2300 15th St. SW
Mason City, IA 50401

**RE: Air Quality Inspection – Notice of Violation**

Dear Mr. Knoll:

As required in your letter dated July 25th, 2013, this letter summarizes the City's actions taken or will take to correct the deficiencies noted in your inspection.

- Applications for construction permits for EP2 (Boiler #1) and EP3 (Boiler #2) have been accomplished and permits have been issued. Permit #'s 13-A-331 (EP-12) and 13-A-332 (EP-13) will replace 12-A-208 and 12-A-209 according to the instructions listed on the permits accompanying cover letter.
- Air Construction Permit Application Forms FI, EU5 for EP-12 and EU5 for EP-13 will be submitted to modify Permit No. 13-A-331 for EP-12 and Permit No. 13-A-332 for EP-13 to reflect the fact that the stacks are vertical with obstructing rain cap.
- New SCADA programming will be implemented into the City's Water Pollution Control Facility that will enable automatic records that will meet or exceed the required record keeping rules for its emergency generators (EP4, EP6, and EP7).

Should you have further questions about the City of Fort Dodge's strategy to reconcile these deficiencies, please feel free to contact me at (515) 576-3601.

Sincerely,

Tony Trotter, PE
Project Engineer

Z:\EPA\Air Quality NOV Response.docx


**Phone: 515.576.3601 Fax: 515.576.5270 E-mail: engineering@fortdodgeiowa.org**