



Report of Investigation

**Department of Natural Resources
Environmental Services Division**

<p align="center">Investigation Date</p> <p>Current: 10/9/2009 Last: none</p>	<p>From: Field Office #2 2300 15th St. SW Mason City, Iowa 50401</p>
<p>To: IDNR Water Supply Engineering Attn: Diana Wilson 401 SW 7th St. Suite M Des Moines, IA 50309</p>	<p>Person(s) Contacted: Tom Grafft - Kuehl & Payer Ltd.</p>
<p>Re: Hawkeye Pride Egg Farms, LLP Well Site Survey - Wells #1 & 2</p>	

A well site survey was conducted in accordance with Subrule 567 IAC 40.2(2). Schedule 1a, 4 and the preliminary engineering report were reviewed as submitted by Neal Kuehl P.E. with Kuehl & Payer, LTD Storm Lake, IA. The well sites were evaluated in accordance with Subrule 567 IAC 43.3(7) and the separation distances listed in Table A Chapter 43. The following observations were made.

1. A total of 7 wells are proposed for this site. Wells #1 & 2 will supply potable water to the egg breaking plant for process water, and for employee use in break rooms, rest rooms, and bio-shower facilities. Wells # 3-7 will supply water to the layer operation and to the heating/cooling system. Wells #3-7 were not surveyed, as they will be considered private wells, not for potable use.
2. According to the site drawing there is a proposed sewer force main to be located 75 feet south of Wells #1 & 2. The force main must be constructed with water main grade pipe.
3. The land use within 200 feet of the well will be controlled through ownership by the water supply.
4. Other potential sources of contamination at the site include a manure storage building and industrial wastewater lagoon. Both structures meet the minimum separation distances. In addition, the floor of the manure storage building will be sloped away from Wells #1 & 2 providing additional protection.
5. The available information indicates that the proposed well sites meet all other listed separation distances.

<p>Inspector Signature:  David Hopper</p>	<p>Date: 11/3/09</p>
<p>Reviewer Signature:  Jeff Vansteenburgh</p>	<p>Date: 11/5/09</p>