

DEPARTMENT OF NATURAL RESOURCES
Environmental Services Division

MEMORANDUM

DATE: April 10, 2024

TO: Kwik Star #1289, Stuart UST File


FROM: Kristi Burg, Environmental Specialist Senior, DNR FO4 *KB*


RE: Installation at Kwik Star 1289, Stuart, IA
Registration #: TBD - New Site

On April 10, 2024, Brent Martens, Environmental Specialist, and I conducted an inspection at the new Kwik Star #1289 facility, located at the NE corner of 110th & Division Streets, Stuart, Iowa. The purpose of the inspection was to observe the installation of the new underground storage tanks for the facility. Installation inspector Nick Petersen, UST Testing, was on site at the time of our visit.

When Brent and I arrived on site, the tanks were already placed in the ground. The submersible pumps were being installed and pea gravel was being backfilled. The facility also installed multiple groundwater monitoring ports. They are the white PVC pipes noted in the photos.

The photos below document our observations.





Stuart041024.ust.KwikStar1289.tank.installation.burg.docx

xc: UST Section, IDNR, Des Moines (via email ustoperations@dnr.iowa.gov)