

**Leachate Elevation Measurements
MidAmerican Energy Company
Walter Scott Jr. Energy Center CCR Monofill
Council Bluffs, Iowa**

Month/Year	Cell Number	Leachate Level Measurement (inches above transducer)	Top of Liner Level (inches above transducer)	Leachate Level Above Top of Liner (inches)	In Compliance (Yes/No)
Jan-2025	Cell 1	10.00	15.2	-5.2	Yes
Jan-2025	Cell 2	17.00	12.7	4.3	Yes
Jan-2025	Cell 3N	16.00	12.9	3.1	Yes
Jan-2025	Cell 3S	19.00	14.6	4.4	Yes
Jan-2025	Cell 4N	20.00	18.7	1.3	Yes
Jan-2025	Cell 4S	23.00	18.7	4.3	Yes
Jan-2025	Cell 5	23.00	18.7	4.3	Yes
Jan-2025	Cell 6N	24.00	18.7	5.3	Yes
Jan-2025	Cell 6S	5.00	18.7	-13.7	Yes
Jan-2025	Cell 7N	17.00	18.7	-1.7	Yes
Jan-2025	Cell 7S	24.00	18.7	5.3	Yes
Jan-2025	Cell 8S	15.00	18.7	-3.7	Yes
Jan-2025	Cell 8C	27.00	18.7	8.3	Yes
Jan-2025	Cell 8N	10.00	18.7	-8.7	Yes
Jan-2025	Cell 9W	23.00	18.7	4.3	Yes
Jan-2025	Cell 9E	11.00	18.7	-7.7	Yes
Feb-2025	Cell 1	15.0	15.2	-0.2	Yes
Feb-2025	Cell 2	9.0	12.7	-3.7	Yes
Feb-2025	Cell 3N	12.0	12.9	-0.9	Yes
Feb-2025	Cell 3S	16.0	14.6	1.4	Yes
Feb-2025	Cell 4N	21.0	18.7	2.3	Yes
Feb-2025	Cell 4S	23.0	18.7	4.3	Yes
Feb-2025	Cell 5	25.0	18.7	6.3	Yes
Feb-2025	Cell 6N	23.0	18.7	4.3	Yes
Feb-2025	Cell 6S	21.0	18.7	2.3	Yes
Feb-2025	Cell 7N	15.0	18.7	-3.7	Yes
Feb-2025	Cell 7S	28.0	18.7	9.3	Yes
Feb-2025	Cell 8S	24.0	18.7	5.3	Yes
Feb-2025	Cell 8C	26.0	18.7	7.3	Yes
Feb-2025	Cell 8N	22.0	18.7	3.3	Yes
Feb-2025	Cell 9W	16.00	18.7	-2.7	Yes
Feb-2025	Cell 9E	20.00	18.7	1.3	Yes
Mar-2025	Cell 1	15.0	15.2	-0.2	Yes
Mar-2025	Cell 2	9.0	12.7	-3.7	Yes
Mar-2025	Cell 3N	15.0	12.9	2.1	Yes
Mar-2025	Cell 3S	18.0	14.6	3.4	Yes
Mar-2025	Cell 4N	17.0	18.7	-1.7	Yes
Mar-2025	Cell 4S	13.0	18.7	-5.7	Yes
Mar-2025	Cell 5	24.0	18.7	5.3	Yes
Mar-2025	Cell 6N	19.0	18.7	0.3	Yes
Mar-2025	Cell 6S	14.0	18.7	-4.7	Yes
Mar-2025	Cell 7N	20.0	18.7	1.3	Yes
Mar-2025	Cell 7S	21.0	18.7	2.3	Yes
Mar-2025	Cell 8S	18.0	18.7	-0.7	Yes
Mar-2025	Cell 8C	27.0	18.7	8.3	Yes
Mar-2025	Cell 8N	20.0	18.7	1.3	Yes
Mar-2025	Cell 9W	23.0	18.7	4.3	Yes
Mar-2025	Cell 9E	25.0	18.7	6.3	Yes

**Leachate Elevation Measurements
MidAmerican Energy Company
Walter Scott Jr. Energy Center CCR Monofill
Council Bluffs, Iowa**

Month/Year	Cell Number	Leachate Level Measurement (inches above transducer)	Top of Liner Level (inches above transducer)	Leachate Level Above Top of Liner (inches)	In Compliance (Yes/No)
Apr-2025	Cell 1	0.0	15.2	-15.2	Yes
Apr-2025	Cell 2	8.0	12.7	-4.7	Yes
Apr-2025	Cell 3N	19.0	12.9	6.1	Yes
Apr-2025	Cell 3S	16.0	14.6	1.4	Yes
Apr-2025	Cell 4N	23.0	18.7	4.3	Yes
Apr-2025	Cell 4S	23.0	18.7	4.3	Yes
Apr-2025	Cell 5	25.0	18.7	6.3	Yes
Apr-2025	Cell 6N	26.0	18.7	7.3	Yes
Apr-2025	Cell 6S	15.0	18.7	-3.7	Yes
Apr-2025	Cell 7N	27.0	18.7	8.3	Yes
Apr-2025	Cell 7S	29.0	18.7	10.3	Yes
Apr-2025	Cell 8S	23.0	18.7	4.3	Yes
Apr-2025	Cell 8C	27.0	18.7	8.3	Yes
Apr-2025	Cell 8N	20.0	18.7	1.3	Yes
Apr-2025	Cell 9W	24.0	18.7	5.3	Yes
Apr-2025	Cell 9E	25.0	18.7	6.3	Yes
May-2025	Cell 1	18.0	15.2	2.8	Yes
May-2025	Cell 2	17.0	12.7	4.3	Yes
May-2025	Cell 3N	16.0	12.9	3.1	Yes
May-2025	Cell 3S	19.0	14.6	4.4	Yes
May-2025	Cell 4N	17.0	18.7	-1.7	Yes
May-2025	Cell 4S	24.0	18.7	5.3	Yes
May-2025	Cell 5	9.0	18.7	-9.7	Yes
May-2025	Cell 6N	17.0	18.7	-1.7	Yes
May-2025	Cell 6S	13.0	18.7	-5.7	Yes
May-2025	Cell 7N	28.0	18.7	9.3	Yes
May-2025	Cell 7S	25.0	18.7	6.3	Yes
May-2025	Cell 8S	21.0	18.7	2.3	Yes
May-2025	Cell 8C	26.0	18.7	7.3	Yes
May-2025	Cell 8N	22.0	18.7	3.3	Yes
May-2025	Cell 9W	23.0	18.7	4.3	Yes
May-2025	Cell 9E	24.0	18.7	5.3	Yes
Jun-2025	Cell 1	12.0	15.2	-3.2	Yes
Jun-2025	Cell 2	9.0	12.7	-3.7	Yes
Jun-2025	Cell 3N	19.0	12.9	6.1	Yes
Jun-2025	Cell 3S	16.0	14.6	1.4	Yes
Jun-2025	Cell 4N	18.0	18.7	-0.7	Yes
Jun-2025	Cell 4S	24.0	18.7	5.3	Yes
Jun-2025	Cell 5	25.0	18.7	6.3	Yes
Jun-2025	Cell 6N	22.0	18.7	3.3	Yes
Jun-2025	Cell 6S	23.0	18.7	4.3	Yes
Jun-2025	Cell 7N	27.0	18.7	8.3	Yes
Jun-2025	Cell 7S	15.0	18.7	-3.7	Yes
Jun-2025	Cell 8S	23.0	18.7	4.3	Yes
Jun-2025	Cell 8C	27.0	18.7	8.3	Yes
Jun-2025	Cell 8N	13.0	18.7	-5.7	Yes
Jun-2025	Cell 9W	25.0	18.7	6.3	Yes
Jun-2025	Cell 9E	24.0	18.7	5.3	Yes

**Leachate Elevation Measurements
MidAmerican Energy Company
Walter Scott Jr. Energy Center CCR Monofill
Council Bluffs, Iowa**

Month/Year	Cell Number	Leachate Level Measurement (inches above transducer)	Top of Liner Level (inches above transducer)	Leachate Level Above Top of Liner (inches)	In Compliance (Yes/No)
Jul-2025	Cell 1	12.0	15.2	-3.2	Yes
Jul-2025	Cell 2	18.0	12.7	5.3	Yes
Jul-2025	Cell 3N	14.0	12.9	1.1	Yes
Jul-2025	Cell 3S	16.0	14.6	1.4	Yes
Jul-2025	Cell 4N	19.0	18.7	0.3	Yes
Jul-2025	Cell 4S	22.0	18.7	3.3	Yes
Jul-2025	Cell 5	16.0	18.7	-2.7	Yes
Jul-2025	Cell 6N	22.0	18.7	3.3	Yes
Jul-2025	Cell 6S	22.0	18.7	3.3	Yes
Jul-2025	Cell 7N	27.0	18.7	8.3	Yes
Jul-2025	Cell 7S	15.0	18.7	-3.7	Yes
Jul-2025	Cell 8S	29.0	18.7	10.3	Yes
Jul-2025	Cell 8C	27.0	18.7	8.3	Yes
Jul-2025	Cell 8N	13.0	18.7	-5.7	Yes
Jul-2025	Cell 9W	29.0	18.7	10.3	Yes
Jul-2025	Cell 9E	25.0	18.7	6.3	Yes
Aug-2025	Cell 1	18.0	15.2	2.8	Yes
Aug-2025	Cell 2	20.0	12.7	7.3	Yes
Aug-2025	Cell 3N	23.0	12.9	10.1	Yes
Aug-2025	Cell 3S	14.0	14.6	-0.6	Yes
Aug-2025	Cell 4N	23.0	18.7	4.3	Yes
Aug-2025	Cell 4S	26.0	18.7	7.3	Yes
Aug-2025	Cell 5	23.0	18.7	4.3	Yes
Aug-2025	Cell 6N	22.0	18.7	3.3	Yes
Aug-2025	Cell 6S	19.0	18.7	0.3	Yes
Aug-2025	Cell 7N	27.0	18.7	8.3	Yes
Aug-2025	Cell 7S	20.0	18.7	1.3	Yes
Aug-2025	Cell 8S	17.0	18.7	-1.7	Yes
Aug-2025	Cell 8C	13.0	18.7	-5.7	Yes
Aug-2025	Cell 8N	17.0	18.7	-1.7	Yes
Aug-2025	Cell 9W	23.0	18.7	4.3	Yes
Aug-2025	Cell 9E	21.0	18.7	2.3	Yes
Sep-2025	Cell 1	20.0	15.2	4.8	Yes
Sep-2025	Cell 2	17.0	12.7	4.3	Yes
Sep-2025	Cell 3N	18.0	12.9	5.1	Yes
Sep-2025	Cell 3S	17.0	14.6	2.4	Yes
Sep-2025	Cell 4N	26.0	18.7	7.3	Yes
Sep-2025	Cell 4S	25.0	18.7	6.3	Yes
Sep-2025	Cell 5	24.0	18.7	5.3	Yes
Sep-2025	Cell 6N	25.0	18.7	6.3	Yes
Sep-2025	Cell 6S	17.0	18.7	-1.7	Yes
Sep-2025	Cell 7N	18.0	18.7	-0.7	Yes
Sep-2025	Cell 7S	25.0	18.7	6.3	Yes
Sep-2025	Cell 8S	19.0	18.7	0.3	Yes
Sep-2025	Cell 8C	27.0	18.7	8.3	Yes
Sep-2025	Cell 8N	20.0	18.7	1.3	Yes
Sep-2025	Cell 9W	26.0	18.7	7.3	Yes
Sep-2025	Cell 9E	21.0	18.7	2.3	Yes

**Leachate Elevation Measurements
MidAmerican Energy Company
Walter Scott Jr. Energy Center CCR Monofill
Council Bluffs, Iowa**

Month/Year	Cell Number	Leachate Level Measurement (inches above transducer)	Top of Liner Level (inches above transducer)	Leachate Level Above Top of Liner (inches)	In Compliance (Yes/No)
Oct-2025	Cell 1	12.0	15.2	-3.2	Yes
Oct-2025	Cell 2	15.0	12.7	2.3	Yes
Oct-2025	Cell 3N	18.0	12.9	5.1	Yes
Oct-2025	Cell 3S	17.0	14.6	2.4	Yes
Oct-2025	Cell 4N	23.0	18.7	4.3	Yes
Oct-2025	Cell 4S	25.0	18.7	6.3	Yes
Oct-2025	Cell 5	24.0	18.7	5.3	Yes
Oct-2025	Cell 6N	21.0	18.7	2.3	Yes
Oct-2025	Cell 6S	17.0	18.7	-1.7	Yes
Oct-2025	Cell 7N	22.0	18.7	3.3	Yes
Oct-2025	Cell 7S	18.0	18.7	-0.7	Yes
Oct-2025	Cell 8S	19.0	18.7	0.3	Yes
Oct-2025	Cell 8C	27.0	18.7	8.3	Yes
Oct-2025	Cell 8N	20.0	18.7	1.3	Yes
Oct-2025	Cell 9W	24.0	18.7	5.3	Yes
Oct-2025	Cell 9E	21.0	18.7	2.3	Yes
Nov-2025	Cell 1	12.0	15.2	5.8	Yes
Nov-2025	Cell 2	15.0	12.7	-0.7	Yes
Nov-2025	Cell 3N	18.0	12.9	5.1	Yes
Nov-2025	Cell 3S	17.0	14.6	2.4	Yes
Nov-2025	Cell 4N	23.0	18.7	4.3	Yes
Nov-2025	Cell 4S	25.0	18.7	6.3	Yes
Nov-2025	Cell 5	24.0	18.7	5.3	Yes
Nov-2025	Cell 6N	21.0	18.7	2.3	Yes
Nov-2025	Cell 6S	17.0	18.7	-1.7	Yes
Nov-2025	Cell 7N	22.0	18.7	3.3	Yes
Nov-2025	Cell 7S	18.0	18.7	-0.7	Yes
Nov-2025	Cell 8S	19.0	18.7	0.3	Yes
Nov-2025	Cell 8C	27.0	18.7	8.3	Yes
Nov-2025	Cell 8N	20.0	18.7	1.3	Yes
Nov-2025	Cell 9W	24.0	18.7	5.3	Yes
Nov-2025	Cell 9E	21.0	18.7	2.3	Yes
Dec-2025	Cell 1	18.0	15.2	2.8	Yes
Dec-2025	Cell 2	22.0	12.7	9.3	Yes
Dec-2025	Cell 3N	18.0	12.9	5.1	Yes
Dec-2025	Cell 3S	25.0	14.6	10.4	Yes
Dec-2025	Cell 4N	23.0	18.7	4.3	Yes
Dec-2025	Cell 4S	14.0	18.7	-4.7	Yes
Dec-2025	Cell 5	24.0	18.7	5.3	Yes
Dec-2025	Cell 6N	21.0	18.7	2.3	Yes
Dec-2025	Cell 6S	24.0	18.7	5.3	Yes
Dec-2025	Cell 7N	22.0	18.7	3.3	Yes
Dec-2025	Cell 7S	25.0	18.7	6.3	Yes
Dec-2025	Cell 8S	19.0	18.7	0.3	Yes
Dec-2025	Cell 8C	26.0	18.7	7.3	Yes
Dec-2025	Cell 8N	20.0	18.7	1.3	Yes
Dec-2025	Cell 9W	27.0	18.7	8.3	Yes
Dec-2025	Cell 9E	25.0	18.7	6.3	Yes

**Leachate Elevation Measurements
MidAmerican Energy Company
Walter Scott Jr. Energy Center CCR Monofill
Council Bluffs, Iowa**

Month/Year	Cell Number	Leachate Level Measurement (inches above transducer)	Top of Liner Level (inches above transducer)	Leachate Level Above Top of Liner (inches)	In Compliance (Yes/No)
------------	-------------	--	--	--	---------------------------

Notes:

The Monofill has been designed with a composite liner system with leachate collection. Leachate is composed of water that percolates through the coal combustion residual (CCR) in the Monofill and may include water soluble compounds from the CCR. Leachate is managed to protect soils, surface water, and groundwater and to maintain the integrity of the composite liner system by preventing a significant accumulation of standing leachate on the liner (e.g. less than 12 inches of head on the liner).

The maximum leachate level allowed is 12 inches above the following measurements. Cell 1 - Top of the Liner Level (TOLL) = 15.2 inches; Cell 2 TOLL = 12.7 inches; Cell 3N TOLL = 12.9 inches; Cell 3S TOLL = 14.6 inches; Cell 4N TOLL = 18.7 inches; Cell 4S TOLL = 18.7 inches; Cell 5 TOLL = 18.7 inches; Cell 6N TOLL = 18.7 inches; Cell 6S TOLL = 18.7 inches; Cell 7N TOLL = 18.7 inches; Cell 7S TOLL = 18.7 inches; Cell 8S TOLL = 18.7 inches; Cell 8C TOLL = 18.7 inches; Cell 8N TOLL = 18.7 inches; Cell 9W TOLL = 18.7 inches; Cell 9E TOLL = 18.7 inches.

Leachate level measurements are calibrated to the cell floor outside the leachate collection sump. The negative values for "Leachate Level Above Top of Liner" indicate leachate was pumped below the cell floor.