



April 21, 2021

CERTIFIED MAIL

JAY SEXTON  
SEXTON OIL CO  
3329 STORY AVE  
DANBURY IA 51019

Subject: **NOTICE OF VIOLATION – OVERDUE COMPLIANCE INSPECTION**  
**Site:** AMOCO PRONTO, 804 4<sup>TH</sup> AVE S., DENISON  
**Registration Number:** 198606429

Dear Mr. Sexton:

The Iowa Department of Natural Resources (Department) records show the biennial compliance inspection of the underground storage tank (UST) system for the above referenced facility is more than 3 months past due. Pursuant IAC 567-135.20 an UST owner or operator must have the UST system inspected and an inspection report submitted to the department by a UST compliance inspector certified by the department under 567—Chapter 134 within 24 months of the prior inspection. The last compliance inspection was on 01/08/2019.

You were sent a notice of violation letter dated 02/19/2021 stating that the compliance inspection was more than 30 days overdue. As of today, the inspection has not been completed or reported to the Department.

In accordance with Iowa Administrative Code 567 – Chapter 135.3(8), you were given 60 days written notice to complete and submit a compliance inspection required by rule 567—135.20(455B) or your site would be placed on delivery prohibition. **Your site is now under delivery prohibition and will be red tagged.** In this event, red-tags will be affixed to the USTs and fuel deliveries will be halted until the delivery prohibition is rescinded and red-tags are properly removed. Once red-tagged it may take up to 5 business days to have the tags removed.

In order to reinstate operations, you, as the UST owner or operator, must submit a compliance inspection report as provided in rule 567 – 135.20 (455B). You will need to contract with an Iowa certified compliance inspector to complete the facility inspection. A list of certified compliance inspectors can be found on our webpage at [www.iowadnr.gov/ust](http://www.iowadnr.gov/ust) under the Licensed UST Professionals tab on the left.

Please contact me at 515-725-8324 or [cody.mccoy@dnr.iowa.gov](mailto:cody.mccoy@dnr.iowa.gov) if you have any questions.

Sincerely,

Cody McCoy  
Environmental Specialist  
Underground Storage Tank Section  
P 515 725 8324 | [cody.mccoy@dnr.iowa.gov](mailto:cody.mccoy@dnr.iowa.gov)

CC Field Office 4 (email)

Jay Sexton, Sexton Oil Co, 3329 Story Ave, Danbury, IA 51019  
Amoco Pronto, 804 4<sup>th</sup> Ave S, Denison, IA 51442