

November 21, 2024

Certified Mail / Email

REHKA KHANNA
SKENTERPRISES INC
12866 HICKORY CT
CLIVE IA 50325

SUBJECT: **NOTICE OF VIOLATION –
Failure to complete a system check (Iowa Administrative Code 567-Chapter 135.6(3)(a))
Facility:** Super Stop Liquor, 2635 Adventureland Drive, Altoona
REGISTRATION #. 199617861

Dear Ms. Khanna,

The Iowa Department of Natural Resources (DNR) was notified by Seneca Companies of the presence of free product at the referenced facility on September 25, 2024. The free product was identified in MW-13 (located south of the far west dispenser) and is the first time free product has been observed in this area of the site. It is unknown if the free product is the result of a new release from the tank system, a spill or migration of contamination associated with one of the prior petroleum releases. In response, the Department issued a letter to you on October 4, 2024 requiring a system test of your UST systems and a full evaluation report by October 23, 2024. To date, no report has been submitted.

We will grant one additional day for the submission of the system evaluation report. If the documents are not received my mail or email (send directly to my attention – james.gastineau@dnr.iowa.gov) by end of the day, the referenced site will be placed on delivery prohibition in accordance with Iowa Administrative Code 567-Chapter 135.3(8)(b)(10) effective November 22, 2024.

Under delivery prohibition, Iowa DNR staff will place red-tags on the fill pipes of each tank. No fuel can be delivered or received into the tanks until such time that the system test and if necessary, a site check is completed in accordance with State regulations, IAC 567-135.6(3)"a".

Please contact me at 515-829-2770 or james.gastineau@dnr.iowa.gov if you have any questions.

Sincerely,

Environmental Specialist Senior
Underground Storage Tank Section
P 515-829-2770

CC: Field Office 5 (email)
Tammy Vander Bloemen, UST Section (email)