

July 2, 2025

Christopher Stell
Sprint Communications Company LP
2450 North Street NW
Washington, DC 20037

Subject: **NOTICE OF VIOLATION – OVERDUE COMPLIANCE INSPECTION**
Sites: Des Moines Pop, 101 SW 16th Street, Des Moines
Cedar Rapids Pop, 170 36th Ave SW, Cedar Rapids
Clinton Pop, 1611 Lincoln Way, Clinton
Registration Numbers: 200000046, 200100031, 200100052

Dear Mr. Stell:

The Iowa Department of Natural Resources (Department) records show the biennial compliance inspections of the underground storage tank (UST) systems for the above referenced facilities are more than 60 days past due. Pursuant IAC 567-135.20 an UST owner or operator must have the UST system inspected and an inspection report submitted to the department by a UST compliance inspector certified by the department under 567—Chapter 134 within 24 months of the prior inspection. The last compliance inspections were on 4/17/2023 and 4/19/2023.

In accordance with Iowa Administrative Code 567 – Chapter 135.3(8), this Notice of Violation (NOV) is to initiate the delivery prohibition process. IAC 567- 135.3(8)"b"(8) provides delivery prohibition will begin if the “owner or operator has failed to complete a compliance inspection required by rule 567—135.20(455B) within 60 days after a written notice of the violation (NOV) by the department”.

A compliance inspection must be completed at each site within 60 days of the date of this letter ,i.e. by September 2, 2025. Failure to have a compliance inspection completed at each site in accordance with rules by close of business on September 2, 2025 will result in each site being placed on a delivery prohibition status. In this event, red-tags will be affixed to the USTs and fuel deliveries will be halted until the delivery prohibition is rescinded and red-tags are properly removed. Additional notices will not be provided.

A list of certified compliance inspectors can be found at <https://programs.iowadnr.gov/ustcert/Home/Search> and type “Compliance Inspector” in the Cert Number & Type box.

Please contact me at 515-805-4521 or cody.mccoy@dnr.iowa.gov if you have any questions.

Sincerely,

Cody McCoy
Environmental Specialist Senior
Underground Storage Tank Section
P 515 805 4521 | cody.mccoy@dnr.iowa.gov

CC Field Office 1,5,6 (via email)
Keith Wilken, UST Section Supervisor (via email)